



**NOTE:**

A. 8-INCH DIAMETER SEWER MAINS AND SMALLER SHALL HAVE A FLOW CHANNEL FORMED AT LEAST TO THE SPRING LINE OF THE PIPE. PIPES GREATER THAN 8" IN DIAMETER SHALL HAVE FLOW CHANNELS FORMED TO THE FULL HEIGHT OF THE CROWN OF THE OUTLET SEWER.

**GENERAL NOTES:**

1. ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING AND TOP SECTION, SHALL BE WATERTIGHT. JOINTING MATERIAL SHALL BE "CONSEAL" OR EQUAL.
2. CONCRETE FOR DROP STRUCTURES SHALL BE FORMED.
3. FLAT-TOP BARREL SHALL BE USED WHEN DISTANCE FROM TOP OF PIPE TO RIM IS LESS THAN 5- FEET.
4. BOLT-DOWN LIDS WILL BE REQUIRED AS PER STD 510. DUSTPANS ARE NOT REQUIRED WITH BOLT-DOWN LIDS.
5. ADDITIONAL FLEX-JOINTS MAY BE INSTALLED WITHIN 2-3 FEET OF MANHOLE WHERE NECESSARY.

December 2021

**Sanitary Sewer Manhole (Sheet 1 of 3)**



Engineering Division

*Ross Mollenhauer*

Approved By City  
Engineer for Utilities  
Ross Mollenhauer, PE

Adopted: 09/28/2020  
Revised: 03/25/2021

**STD - 512-1**