



GENERAL NOTES:

1. PUMP SIZE AND TYPE WILL BE DETERMINED ON AN INDIVIDUAL BASIS
2. FOR CONNECTIONS TO GRAVITY MAINS ONLY
3. EJECTOR PUMPS SHALL BE OWNED AND MAINTAINED ENTIRELY BY THE PRIVATE HOME OWNER. AS SUCH THEY SHALL BE LOCATED ON PRIVATE PROPERTY ONLY.
4. COMMERCIAL EJECTOR SYSTEMS REQUIRE 2 PUMPS

December 2021



Engineering Division

External Ejector Pump Standard

Approved By Utility
Project Manager –
Ross Mollenhauer, PE

Revised: 09/28/2020

STD - 541