



KEYED NOTES:

- ① SURFACING: WHEN ASPHALT IS SPECIFIED, IT SHALL BE A MINIMUM OF 3 INCHES THICKNESS OF GRADE C, PG 58-28 MIX IN ACCORDANCE WITH CITY OF MISSOULA MODIFICATION TO MPWSS SECTION 02510. WHEN CONCRETE IS SPECIFIED, SEE THE MATERIAL AND THICKNESS REQUIREMENTS OF CITY OF MISSOULA MODIFICATION TO THE MPWSS SECTION 02529 AND MCPWSS CHAPTER 7 FOR CONCRETE SIDEWALKS.
- ② BASE COURSE: 6" MINIMUM (ASPHALT) OR 4" MINIMUM (CONCRETE) IN ACCORDANCE WITH CITY OF MISSOULA MODIFICATION TO MPWSS SECTION 02235.
- ③ SUBGRADE: SEE CITY OF MISSOULA MODIFICATION TO MPWSS SECTION 02230.
- ④ SHOULDER: MAX SLOPE SHALL BE 6H:1V AND SHALL BE FREE OF LATERAL OBSTRUCTIONS INCLUDING SIGNS, FENCES, BOULDERS, VEGETATION, STRUCTURES, AND SLOPES EXCEEDING 6:1. WHERE A LESS THAN 5' SHOULDER WIDTH IS ADJACENT TO A PARALLEL BODY OF WATER AND/OR A STEEP FORESLOPE ($\geq 3:1$), INCORPORATE A PHYSICAL BARRIER OR RAIL IN ACCORDANCE WITH THE RECOMMENDATIONS IN THE AASHTO GUIDE FOR THE DEVELOPMENT OF BICYCLE FACILITIES, SECTION 5.2.1.
- ⑤ FORESLOPES: MAXIMUM SLOPE SHALL BE LESS THAN 3:1.
- ⑥ BACKSLOPES: MAXIMUM SLOPE SHALL BE LESS THAN 2:1.
- ⑦ SOIL STERILANT SHALL BE A COMMERCIAL GRADE TRIFLURALIN (TREFLAN) AT A RATE OF 11 FLUID OUNCES PER 1,000 SQ FT OR DICHLOBENIL (CASORON 4G) AT A RATE OF 6 LBS PER 1,000 SQ FT ON DRY SITES AND AQUATICALLY LABELED IMAZAPYR (HABITAT) 1.1 FLUID OUNCES PER 1,000 SQ FT ON WET OR AQUATIC SITES. PAVE SHORTLY AFTER APPLICATION, WITH A MAXIMUM EXPOSURE TIME OF SIX HOURS.

GENERAL NOTES:

1. SURFACING CROSS-SLOPE MAY BE CROWNED OR CONTINUOUS BASED ON DRAINAGE NEEDS AND SHALL NOT EXCEED THE ADA/PROWAG MAXIMUM RUNNING AND CROSS SLOPE.



Engineering Division

Typical Shared-Use Path Section

Approved By
City Engineer
Kevin J. Slovarp

Adopted: 01/01/2023

Revised:

STD - 749