



GENERAL NOTES:

1. ALL JOINTS BETWEEN MANHOLE SECTIONS, ADJUSTING RINGS, MANHOLE RING AND TOP SECTION, SHALL BE WATERTIGHT. JOINTING MATERIAL SHALL BE "RAM-NEK®" OR EQUAL.
2. CONCRETE FOR DROP STRUCTURES SHALL BE FORMED.

MANHOLE-TO-PIPE DATA TABLE			
MANHOLE DIA.	WALL THICKNESS	PIPE DIA >	PIPE DIA ≤
4'-0"	0'-5"	---	18"
5'-0"	0'-6"	18"	24"
6'-0"	0'-7"	24"	54"
JUNCTION BOX	---	54"	---

*MINIMUM PIPE DIAMETER FOR PUBLIC MAINS/LATERALS = 12 INCHES



Engineering Division

Storm Water Manhole (Sheet 1 of 3)

AS

Approved By
Utility Engineer
Andy Schultz, PE

Revised: 09/28/2020

STD - 612-1