



NOTE: RESTRAINED JOINTS WITHIN 36 FEET OF VALVE WITH MEGALUGS, FIELD LOK GASKETS, OR APPROVED EQUIVALENT.



Engineering Division

Valve Detail

Logan McInnis

Approved By
Utilities Engineer
Logan McInnis, PE

Adopted: 09/28/2020
Revised: 02/04/2021

STD - 405