



NOTE:

- A. WHERE THERE IS A UTILITY EASEMENT ADJACENT TO THE RIGHT-OF-WAY, METER PIT CAN BE LOCATED 2' ON THE BUILDING SIDE OF THE EASEMENT.

GENERAL NOTES:

1. FOR COMMERCIAL SERVICES SMALLER THAN 4", SEE CITY STANDARD DETAIL STD-404B.
2. VALVE SHALL REMAIN CLOSED UNTIL CONNECTION TO THE BUILDING.
3. WATER SERVICES SHALL BE BURIED A MINIMUM OF 6' DEEP.
4. IF PROPERTY DOES NOT FRONT A STREET WITH A WATER MAIN, CONTACT CITY FOR SPECIFIC REQUIREMENTS RELATED TO EASEMENTS.
5. SERVICE LINE SHALL END AT WOOD POST. IT IS THE INSTALLER'S RESPONSIBILITY TO REMOVE AIR FROM THE SERVICE LINES AS NECESSARY.
6. WATER SERVICE STUBS SHALL BE INSTALLED WHERE SHOWN ON THE DRAWINGS OR AS SPECIFIED BY CITY ENGINEERING.

December 2021



Engineering Division

Typical 4-Inch and Larger Water Service Stub Detail

Logan McInnis

Approved By
Utilities Engineer
Logan McInnis, PE

Revised: 09/28/2020

STD - 413