


NOTE: NO UNRESTRAINED JOINTS
WITHIN 36 FEET OF BLOWOFF



GENERAL NOTES:

1. CONSTRUCTION MATERIALS AND PROCEDURES SHALL COMPLY WITH MONTANA PUBLIC WORKS STANDARD SPECIFICATIONS (MPWSS), 7TH EDITION, APRIL 2021, AS MODIFIED BY THE MISSOULA CITY PUBLIC WORKS STANDARDS AND SPECIFICATIONS MANUAL, APPENDIX 2-A (STANDARD MODIFICATIONS TO MPWSS), CURRENT EDITION.
2. ROAD BOXES TO BE PLACED FLUSH TO 1/4" BELOW FINISHED GRADE IN HARD SURFACE.