



GENERAL NOTES:

1. CONSTRUCTION MATERIALS AND PROCEDURES SHALL COMPLY WITH MONTANA PUBLIC WORKS STANDARD SPECIFICATIONS (MPWSS), 7TH EDITION, APRIL 2021, AS MODIFIED BY THE MISSOULA CITY PUBLIC WORKS STANDARDS AND SPECIFICATIONS MANUAL, APPENDIX 2-A (STANDARD MODIFICATIONS TO MPWSS), CURRENT EDITION.
2. CONTRACTOR SHALL INSTALL EXTERNAL JOINT WRAP ON ALL WET WELL JOINTS PRIOR TO APPLYING EXTERNAL COATING.
3. ALL EXPOSED DUCTILE IRON PIPE AND FITTINGS SHALL BE FIELD COATED WITH A POLYAMIDE EPOXY COATING PER MPWSS SECTION 02730 AS MODIFIED BY THE CITY OF MISSOULA.



Engineering Division

Standard Sewer Lift Station - Sheet 1 of 3

Approved By Utility Project
Manager - Ross
Mollenhauer, PE

Adopted: 09/28/2020
Revised: 01/01/2023

STD - 550