

ELEVATION CERTIFICATE

Important: Read the instructions on pages 1-8.

e

SECTION A - PROPERTY INFORMATION

A1 Building Owner's Name Hoyt Homes		For Insurance Company Use:
A2 Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No. 2722 Roderick Way		Policy Number
City Missoula State MT ZIP Code 59808		Company NAIC Number

A3. Property Description (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.)
Lot 18, Stream Side

A4. Building Use (e.g., Residential, Non-Residential, Addition, Accessory, etc.) Residential

A5. Latitude/Longitude: Lat. 46°52'25.4"N Long. 114°02'40.2"

Horizontal Datum: NAD 1927 NAD 1983

A6. Attach at least 2 photographs of the building if the Certificate is being used to obtain flood insurance.

A7. Building Diagram Number 8

A8. For a building with a crawl space or enclosure(s), provide

- a) Square footage of crawl space or enclosure(s) 1825sq ft
- b) No. of permanent flood openings in the crawl space or enclosure(s) walls within 1.0 foot above adjacent grade NA
- c) Total net area of flood openings in A8.b NA sq in

A9. For a building with an attached garage, provide:

- a) Square footage of attached garage 600 sq ft
- b) No. of permanent flood openings in the attached garage walls within 1.0 foot above adjacent grade NA
- c) Total net area of flood openings in A9.b NA sq in

SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION

B1. NFIP Community Name & Community Number City of Missoula 300049		B2. County Name Missoula		B3. State Montana	
B4. Map/Panel Number 30063 C1460	B5. Suffix D	B6. FIRM Index Date 8/16/1988	B7. FIRM Panel Effective/Revised Date 8/16/1988	B8. Flood Zone(s) X	B9. Base Flood Elevation(s) (Zone AO, use base flood depth) N/A Zone X

B10. Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in Item B9.

FIS Profile FIRM Community Determined Other (Describe) _____

B11. Indicate elevation datum used for BFE in Item B9: NGVD 1929 NAVD 1988 Other (Describe) _____

B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)? Yes No
Designation Date _____ CBRS OPA

SECTION C - BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)

C1. Building elevations are based on: Construction Drawings* Building Under Construction* Finished Construction
*A new Elevation Certificate will be required when construction of the building is complete.

C2. Elevations – Zones A1-A30, AE, AH, A (with BFE), VE, V1-V30, V (with BFE), AR, AR/A, AR/AE, AR/A1-A30, AR/AH, AR/AO. Complete Items C2.a-g below according to the building diagram specified in Item A7.

Benchmark Utilized WGM TBM2 Vertical Datum NAVD88

Conversion/Comments NGVD29 to NAVD88 is +3.58'

Check the measurement used.

- a) Top of bottom floor (including basement, crawl space, or enclosure floor) 3149.6 feet meters (Puerto Rico only)
- b) Top of the next higher floor 3154.5 feet meters (Puerto Rico only)
- c) Bottom of the lowest horizontal structural member (V Zones only) 3152.9 feet meters (Puerto Rico only)
- d) Attached garage (top of slab) 3154.5 feet meters (Puerto Rico only)
- e) Lowest elevation of machinery or equipment servicing the building (Describe type of equipment in Comments) 3152.9 feet meters (Puerto Rico only)
- f) Lowest adjacent (finished) grade (LAG) 3152.9 feet meters (Puerto Rico only)
- g) Highest adjacent (finished) grade (HAG) 3152.9 feet meters (Puerto Rico only)

SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information. *I certify that the information on this Certificate represents my best efforts to interpret the data available.*
I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.


Check here if comments are provided on back of form.

Certifier's Name **Ryan J. Salisbury PE** License Number **13610**

Professional Engineer Company Name **WGM Group**

Address **3021 Palmer St** City **Missoula** State **MT** ZIP Code **59808**

Signature *Ryan J. Salisbury* Date **7/29/2008** Telephone **406-728-4611**



IMPORTANT: In these spaces, copy the corresponding information from Section A.

For Insurance Company Use:

Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No.
2722 Roderick Way

Policy Number

City Missoula State MT ZIP Code 59808

Company NAIC Number

SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION (CONTINUED)

Copy both sides of this Elevation Certificate for (1) community official, (2) insurance agent/company, and (3) building owner.

Comments See Attachment

*Ryan J. Salisbury**7-29-08*

Signature Ryan J. Salisbury PE

Date 7/29/2008

 Check here if attachments**SECTION E - BUILDING ELEVATION INFORMATION (SURVEY NOT REQUIRED) FOR ZONE AO AND ZONE A (WITHOUT BFE)**

For Zones AO and A (without BFE), complete Items E1-E5. If the Certificate is intended to support a LOMA or LOMR-F request, complete Sections A, B, and C. For Items E1-E4, use natural grade, if available. Check the measurement used. In Puerto Rico only, enter meters.

E1. Provide elevation information for the following and check the appropriate boxes to show whether the elevation is above or below the highest adjacent grade (HAG) and the lowest adjacent grade (LAG).

- a) Top of bottom floor (including basement, crawl space, or enclosure) is _____ feet meters above or below the HAG.
 b) Top of bottom floor (including basement, crawl space, or enclosure) is _____ feet meters above or below the LAG.

E2. For Building Diagrams 6-8 with permanent flood openings provided in Section A Items 8 and/or 9 (see page 8 of Instructions), the next higher floor (elevation C2.b in the diagrams) of the building is _____ feet meters above or below the HAG.E3. Attached garage (top of slab) is _____ feet meters above or below the HAG.E4. Top of platform of machinery and/or equipment servicing the building is _____ feet meters above or below the HAG.E5. Zone AO only: If no flood depth number is available, is the top of the bottom floor elevated in accordance with the community's floodplain management ordinance? Yes No Unknown. The local official must certify this information in Section G.**SECTION F - PROPERTY OWNER (OR OWNER'S REPRESENTATIVE) CERTIFICATION**The property owner or owner's authorized representative who completes Sections A, B, and E for Zone A (without a FEMA-issued or community-issued BFE) or Zone AO must sign here. *The statements in Sections A, B, and E are correct to the best of my knowledge.*

Property Owner's or Owner's Authorized Representative's Name

Address _____ City _____ State _____ ZIP Code _____

Signature _____ Date _____ Telephone _____

Comments _____

 Check here if attachments**SECTION G - COMMUNITY INFORMATION (OPTIONAL)**

The local official who is authorized by law or ordinance to administer the community's floodplain management ordinance can complete Sections A, B, C (or E), and G of this Elevation Certificate. Complete the applicable item(s) and sign below. Check the measurement used in Items G8. and G9.

G1. The information in Section C was taken from other documentation that has been signed and sealed by a licensed surveyor, engineer, or architect who is authorized by law to certify elevation information. (Indicate the source and date of the elevation data in the Comments area below.)G2. A community official completed Section E for a building located in Zone A (without a FEMA-issued or community-issued BFE) or Zone AO.G3. The following information (Items G4.-G9.) is provided for community floodplain management purposes.

G4. Permit Number	G5. Date Permit Issued	G6. Date Certificate Of Compliance/Occupancy Issued
-------------------	------------------------	---

G7. This permit has been issued for: New Construction Substantial ImprovementG8. Elevation of as-built lowest floor (including basement) of the building: _____ feet meters (PR) Datum _____G9. BFE or (in Zone AO) depth of flooding at the building site: _____ feet meters (PR) Datum _____

Local Official's Name _____ Title _____

Community Name _____ Telephone _____

Signature _____ Date _____

Comments _____

 Check here if attachments

Post Construction Elevation Certificate for Lot 18 of Stream Side Subdivision
Section D – Continued

The FEMA Form 81-31 is not applicable in areas designated as Zone X (areas determined to be outside 500-year floodplain). This certificate is being completed as a condition of subdivision approval imposed by the City of Missoula on the Stream Side subdivision. The condition requires “the lowest floor, including basements, of any structure anywhere on the property shall be at least 2' above the 100-year flood elevation of the Clark Fork River. Crawlspace floors may be at or above the elevation of the 100-year flood if they do not contain mechanical equipment. Elevation Certificates shall be submitted documenting the lowest floor and utility elevations are a minimum of 2' above the base flood elevation”.

The 100-year flood elevation on the adjacent Clark Fork River area is interpolated to be 3149.6 based on a NAVD 1988 datum.

By field survey on June 4, 2007, the finished floor of the residence is constructed to elevation 3154.5, which is 2.9 feet above the minimum required. The crawl space is at an elevation of 3149.6, which is equal to the minimum required. The garage floor is constructed to elevation 3152.9, which is 3.3 feet above the minimum required. The mechanical room is on the main floor at elevation 3154.5, which is 2.9 feet above the minimum required.

The structure meets the condition imposed by the subdivision approval.