



For SI: 1 foot = 304.8 mm.

**Figure 503.1.1(1)
FIRE DEPARTMENT ACCESS—LARGE BUILDING**

NOTES:

An access road is required to extend within 150 feet of all portions along the exterior wall of the grade level story of each new or relocated building.



Standard Detail (STD) Fire Department Access Large Building Figure IFC 503.1.1(1)

APPROVED BY	SCALE: N.T.S.
DAX FRASER, FIRE MARSHAL	DATE: 05/19/2021
MFD FIRE PREVENTION BUREAU	FIGURE BY: ICC

STD - 503.1.1(1)