



NOTES:

A clear space of 3 feet must be maintained around hydrants (Figure 508.5.5) to allow for hose connections with hydrant/spanner wrenches or other tools. Note that hydrant clearances apply to installation of hydrant impact protection features (Figure 508.5.6).



Standard Detail (STD) Fire Hydrant Clearance-Impact Protection Figures IFC 508.5.5, 508.5.6

APPROVED BY	SCALE: N.T.S.
DAX FRASER, FIRE MARSHAL	DATE: 05/19/2021
MFD FIRE PREVENTION BUREAU	FIGURE & TABLE BY: ICC

STD - 508.5.5, 508.5.6